

CHECKLIST FOR LOW PRESSURE LATERAL INSTALLATION

- Field draft
- Final with signed field draft attached

Job No. Chatham Sewer Ph. 2
 Contract No. 2017-CWMP-1
 Contractor ROBERT B. OVA Co. Inc

Date work completed 2-19-18

Street ABSEGAMI RUN House No. # 130
 Sewer Main Size 2" FUSION

| ITEM | | LOCATION SKETCH |
|---|--------|-----------------|
| 1. Connection to Main Sewer | | SEE BACK |
| (a) Made with fused tee | ✓ | |
| (b) Made with cast iron saddle or plastic saddle | — | |
| (c) Encased with concrete | — | |
| 2. Service Lateral Pipe Installed | | |
| (a) Using PE pipe | ✓ | |
| (b) Using Schedule 40 PVC | — | |
| (c) Using PVC pipe | — | |
| (d) Using plug at end of pipe | ✓ | |
| 3. Following Backfill of Pipe | | |
| (a) Stake set over end of lateral | ✓ | |
| (b) Stake marked to show depth of invert of pipe | ✓ | |
| 4. Service Lateral Diameter (inches) | 1 1/4" | |
| 5. Approximate depth Below Grade to Invert at Service Lateral End (feet/inches) | 5' | |

CHECKED AND APPROVED

INSTRUCTIONS:

Complete every space accurately and sign in field.
 Show house and street outlines.
 Show a minimum of two referenced radius ties to permanent objects shown on Contract Drawings.
 Show station of wye fitting.

Ben Montano 2-19-18
 Contractor's Representative, date

R. B. 2/20/18
 Resident Project Representative, date

Copies for Owner, Field, and Office

END OF SECTION

A-C 63'6"
B-C 25'9"

