

CHECKLIST FOR LOW PRESSURE LATERAL INSTALLATION

Contractor C.C. CONSTRUCTION, INC.
 Date work completed JANUARY 6TH, 2020

Job No. 01190477
 Contract No. 2018-CWMP-2

Property Address #159 WILFRED ROAD Street served from: WILFRED ROAD
 Sewer Main Size [1.5] [2.0] [3.0] [4.0]

ITEM		LOCATION SKETCH	
1.	Connection to Main Sewer		
(a)	Made with fused tee		✓
(b)	Made with cast iron saddle or plastic saddle		N/A
(c)	Encased with concrete		N/A
2.	Service Lateral Pipe Installed		
(a)	Using PE pipe		✓
(b)	Using Schedule 40 PVC		N/A
(c)	Using PVC pipe		N/A
(d)	Using plug at end of pipe		END CAP
3.	Following Backfill of Pipe		
(a)	Stake set over end of lateral		✓
(b)	Stake marked to show depth of invert of pipe		N/A
4.	Service Lateral Diameter (inches)		1.25"
5.	Approximate depth Below Grade to Invert at Service Lateral End (feet/inches)		4.0'

CHECKED AND APPROVED

INSTRUCTIONS:
 Complete every space accurately and sign in field.
 Show house and street outlines.
 Show a minimum of three referenced radius ties to permanent objects shown on Contract Drawings.

David A. Ted 1.13.20
 Contractor's Representative, date

Kenneth Hodges 2-10-20
 Resident Project Representative, date

Copies for Owner, Field, and Office

END OF SECTION