

CHECKLIST FOR LOW PRESSURE LATERAL INSTALLATION

- Field draft
- Final with signed field draft attached

Job No. Chatham Phase 2  
 Contract No. 2017-CWMP-1  
 Contractor Robert B. Ourco, INC


Date work completed 11/19/18

Street Wineberry Rd House No. 34  
 Sewer Main Size 12

ITEM		LOCATION SKETCH
1. Connection to Main Sewer		SEE BACK
(a) Made with fused tee	—	
(b) Made with cast iron saddle or plastic saddle	✓	
(c) Encased with concrete	—	
2. Service Lateral Pipe Installed		
(a) Using PE pipe	✓	
(b) Using Schedule 40 PVC	—	
(c) Using PVC pipe	—	
(d) Using plug at end of pipe	✓	
3. Following Backfill of Pipe		
(a) Stake set over end of lateral	✓	
(b) Stake marked to show depth of invert of pipe	✓	
4. Service Lateral Diameter (inches)	1.25"	
5. Approximate depth Below Grade to Invert at Service Lateral End (feet/inches)	5'	

CHECKED AND APPROVED

**INSTRUCTIONS:**  
 Complete every space accurately and sign in field.  
 Show house and street outlines.  
 Show a minimum of two referenced radius ties to permanent objects shown on Contract Drawings.  
 Show station of wye fitting.

  
 \_\_\_\_\_  
 Contractor's Representative, date

\_\_\_\_\_  
 Resident Project Representative, date

Copies for Owner, Field, and Office

END OF SECTION

34 wineberry way

